

**TABELA DE ANALISE DE AGUA  
SAMAE DE SANGÃO-SC**

**Localidade: ETA ÁGUA BOA  
Primeiro Semestre de 2025**

| <b>SEMESTRAL</b>                                                   |                         |                    |
|--------------------------------------------------------------------|-------------------------|--------------------|
| <b>PARAMETRO</b>                                                   | <b>RESULTADO</b>        | <b>LEGISLAÇÃO</b>  |
| <b>Alaclor - VMP: 20,0 µg/L</b>                                    | <b>&lt;10 µg/L</b>      | <b>≤ 20 µg/L</b>   |
| <b>Aldicarbe +<br/>Aldicarbessulfona +<br/>Aldicarbessulfóxido</b> | <b>&lt; 6 µg/L</b>      | <b>≤ 10 µg/L</b>   |
| <b>Aldrin + Dieldrin - VMP:<br/>0,03 µg/L</b>                      | <b>&lt; 0,003 µg/L</b>  | <b>≤ 0,03 µg/L</b> |
| <b>Atrazina - VMP: 2,0 µg/L</b>                                    | <b>&lt; 0,5 µg/L</b>    | <b>≤ 2,0 µg/L</b>  |
| <b>Carbendazim + benomil -<br/>VMP: 120,0 µg/L</b>                 | <b>&lt; 40 µg/L</b>     | <b>≤ 120 µg/L</b>  |
| <b>Carbofurano - VMP: 7,0<br/>µg/L</b>                             | <b>&lt; 2 µg/L</b>      | <b>≤ 7 µg/L</b>    |
| <b>Clordano - VMP: 0,2 µg/L</b>                                    | <b>&lt; 0,1 µg/L</b>    | <b>≤ 0,5 µg/L</b>  |
| <b>Clorpirifós + clorpirifós-<br/>oxon - VMP: 30,0 µg/L</b>        | <b>&lt; 20 µg/L</b>     | <b>≤ 30 µg/L</b>   |
| <b>DDT + DDD + DDE - VMP:<br/>1,0 µg/L</b>                         | <b>&lt; 0,0020 µg/L</b> | <b>≤ 1 µg/L</b>    |
| <b>Diuron - VMP: 90,0 µg/L</b>                                     | <b>&lt; 10 µg/L</b>     | <b>≤ 20 µg/L</b>   |
| <b>Glifosato + AMPA - VMP:<br/>500,0 µg/L</b>                      | <b>&lt; 60 µg/L</b>     | <b>≤ 500 µg/L</b>  |
| <b>Lindano (gama HCH) -<br/>VMP: 2,0 µg/L</b>                      | <b>&lt; 0,010 µg/L</b>  | <b>≤ 2 µg/L</b>    |
| <b>Mancozebe - VMP: 180,0<br/>µg/L</b>                             | <b>&lt; 1 µg/L</b>      | <b>≤ 8 µg/L</b>    |
| <b>Metamidofós - VMP: 12,0<br/>µg/L</b>                            | <b>&lt; 1 µg/L</b>      | <b>≤ 7 µg/L</b>    |

|                                          |                      |                   |
|------------------------------------------|----------------------|-------------------|
| <b>Metolaclo-ro - VMP: 10,0<br/>µg/L</b> | <b>&lt; 10 µg/L</b>  | <b>≤ 10 µg/L</b>  |
| <b>Molinato - VMP: 6,0 µg/L</b>          | <b>&lt; 5 µg/L</b>   | <b>≤ 6 µg/L</b>   |
| <b>Profenofós - VMP: 60,0<br/>µg/L</b>   | <b>&lt; 0,1 µg/L</b> | <b>≤ 0,3 µg/L</b> |
| <b>Simazina - VMP: 2,0 µg/L</b>          | <b>&lt; 1 µg/L</b>   | <b>≤ 2 µg/L</b>   |
| <b>Tebuconazol - VMP: 180,0<br/>µg/L</b> | <b>&lt; 100 µg/L</b> | <b>≤ 180 µg/L</b> |
| <b>Terbufós - VMP: 1,2 µg/L</b>          | <b>&lt; 0,1 µg/L</b> | <b>≤ 1,2 µg/L</b> |
| <b>Trifluralina - VMP: 20,0 µg/L</b>     | <b>&lt; 10 µg/L</b>  | <b>≤ 20 µg/L</b>  |