

**TABELA DE ANALISE DE AGUA
SAMAE DE SANGÃO-SC**

**Localidade: ETA ÁGUA BOA
Segundo Semestre de 2025**

SEMESTRAL		
PARAMETRO	RESULTADO	LEGISLAÇÃO
Alaclor - VMP: 20,0 µg/L	<10 µg/L	≤ 20 µg/L
Aldicarbe + Aldicarbessulfona + Aldicarbessulfóxido	< 6 µg/L	≤ 10 µg/L
Aldrin + Dieldrin - VMP: 0,03 µg/L	< 0,003 µg/L	≤ 0,03 µg/L
Atrazina - VMP: 2,0 µg/L	< 0,5 µg/L	≤ 2,0 µg/L
Carbendazim + benomil - VMP: 120,0 µg/L	< 40 µg/L	≤ 120 µg/L
Carbofurano - VMP: 7,0 µg/L	< 2 µg/L	≤ 7 µg/L
Clordano - VMP: 0,2 µg/L	< 0,1 µg/L	≤ 0,5 µg/L
Clorpirifós + clorpirifós- oxon - VMP: 30,0 µg/L	< 20 µg/L	≤ 30 µg/L
DDT + DDD + DDE - VMP: 1,0 µg/L	< 0,0020 µg/L	≤ 1 µg/L
Diuron - VMP: 90,0 µg/L	< 10 µg/L	≤ 20 µg/L
Glifosato + AMPA - VMP: 500,0 µg/L	< 60 µg/L	≤ 500 µg/L
Lindano (gama HCH) - VMP: 2,0 µg/L	< 0,010 µg/L	≤ 2 µg/L
Mancozebe - VMP: 180,0 µg/L	< 1 µg/L	≤ 8 µg/L
Metamidofós - VMP: 12,0 µg/L	< 1 µg/L	≤ 7 µg/L

Metolaclo-ro - VMP: 10,0 µg/L	< 10 µg/L	≤ 10 µg/L
Molinato - VMP: 6,0 µg/L	< 5 µg/L	≤ 6 µg/L
Profenofós - VMP: 60,0 µg/L	< 0,1 µg/L	≤ 0,3 µg/L
Simazina - VMP: 2,0 µg/L	< 1 µg/L	≤ 2 µg/L
Tebuconazol - VMP: 180,0 µg/L	< 100 µg/L	≤ 180 µg/L
Terbufós - VMP: 1,2 µg/L	< 0,1 µg/L	≤ 1,2 µg/L
Trifluralina - VMP: 20,0 µg/L	< 10 µg/L	≤ 20 µg/L